

## **Charcoal/Wood (Solid Fuel) Cooking**

1. Charcoal appliances shall be placed a safe distance away, in an open area outside of tent or structure. IFC 3104.7
2. Charcoal appliances shall be installed on noncombustible surface, be properly supported and protected.
3. Only approved charcoal lighter fluid shall be used to start the fire, and once the fire is ignited lighter fluid shall be removed from the booth and stored properly. (50 feet) IFC 2404.17.2 Charcoal chimneys that do not require starter fluid for starting an appliance are recommended and accepted.
4. Shall have a Class "K" fire extinguisher for solid fuel with current inspection tag. IFC 904.12.5.1