

## **Mobile Food Vehicles**

The following are requirements for ALL mobile food trucks and enclosed trailers;

- 1.** All trucks and enclosed trailers that produce grease laden vapors must have a Type 1 hood. IFC 609.2, and maintained and operated with current inspection tags IFC 609.3
- 2.** Each Type 1 hood shall be protected with an approved automatic fire-extinguishing system installed in accordance with IFC code. IFC 904.2.2
- 3.** Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. All employees working in the vehicle shall be trained in the proper use of the fire extinguishers. Fire extinguishers shall bear a current inspection tag validated within the past twelve months OR a receipt of purchase within the last 12 months shall be available for inspection. IFC 901.6, 906.1, 906.5, 904.12.5 (cooking), 6108.2 (LPG), NFPA 10-07 & NFPA 96-08
  - a. Vehicles using a liquid or gas fuel source shall have a minimum 2A:20-B:C fire extinguisher.
  - b. Vehicles using a solid fuel source shall have a minimum of a 6L Class K fire extinguisher for solid fuel.
  - c. Vehicles that have a deep fat fryer shall have a 6L Class “K” rated fire extinguisher. IFC 904.12.5.2
- 4.** All compressed gas cylinders shall be protected and secured to prevent falling, or physical impact. IFC 5303.5
- 5.** LPG pressure relief valves shall be located within a safe distance away from any ignition source (open flame or generator). 3804.3 (e2) (ie. 5 feet)
- 6.** A “No Smoking” sign next to or directly above the propane container and visible to the public. Such sign shall be posted with a minimum of 2 inch lettering. NYSFC 310.3, 3807.2
- 7.** Shall be equipped with a working carbon monoxide detector that meets standards set forth in NFPA 1192-6.4.6. and equipped with a leak indicator according to NFPA 1192-6.4.8.
- 8.** Refer to other sections of this document where they may apply.